

## Technical Information

**STF700 SmartLine Flange Mounted Level Specification 34-ST-03-103, February 2018****Introduction**

Part of the SmartLine® family of products, the STF700 is suitable for monitoring, control and data acquisition.

STF700 products feature piezoresistive sensor technology combining pressure sensing with on chip temperature compensation capabilities providing high accuracy, stability and performance over a wide range of application pressures and temperatures. The SmartLine family is also fully tested and compliant with Experion® PKS providing the highest level of compatibility assurance and integration capabilities. SmartLine easily meets the most demanding application needs for pressure measurement applications.

**Best in Class Features:**

- Accuracies up to 0.05% standard
- Stability up to 0.02% of URL per year for ten years
- Automatic static pressure & temperature compensation
- Rangeability up to 100:1
- Response times as fast as 90ms
- Multiple local display capabilities
- External zero, span, & configuration capability
- Polarity insensitive electrical connections
- Comprehensive on-board diagnostic capabilities
- Integral Dual Seal design for highest safety based on ANSI/NFPA 70-202 and ANSI/ISA 12.27.0
- World class overpressure protection
- Full compliance to SIL 2/3 requirements.
- Modular design characteristics



**Figure 1 – STF700 Flanged Level Transmitters feature field-proven piezoresistive sensor technology**

**Span & Range Limits:**

Model	URL “H <sub>2</sub> O (mbar)	LRL “H <sub>2</sub> O (mbar)	Max Span “H <sub>2</sub> O (mbar)	Min Span “H <sub>2</sub> O (mbar)
STF724	400 (1000)	-400 (-1000)	400 (1000)	4.0 (10.0)
STF72F	400 (1000)	-400 (-1000)	400 (1000)	4.0 (10.0)
Model	psi (bar)	psi (bar)	psi (bar)	psi (bar)
STF732	100 (7.0)	-100 (-7.0)	100 (7.0)	1 (0.07)
STF73F	100 (7.0)	-100 (-7.0)	100 (7.0)	1 (0.07)

**Communications/Output Options:**

- 4-20mA dc
- Honeywell Digitally Enhanced (DE)
- HART® (version 7.0)
- FOUNDATION™ Fieldbus

All transmitters are available with the above listed communications protocols.

## Description

The SmartLine family pressure transmitters are designed around a high performance piezo-resistive sensor. This one sensor actually integrates multiple sensors linking process pressure measurement with on-board static pressure (DP Models) and temperature compensation measurements. This level of performance allows the ST 700 to replace most competitive transmitters available today.

## Indication/Display Option

The ST 700 modular design accommodates a basic alphanumeric LCD display.

### Basic Alphanumeric LCD Display Features

- Modular (may be added or removed in the field)
- 0, 90, 180, & 270 degree position adjustments
- Configurable (HART only) and standard (Pa, KPa, MPa, KGcm<sup>2</sup>, Torr, ATM, inH<sub>2</sub>O, mH<sub>2</sub>O, bar, mbar, inH<sub>2</sub>O, inHG, FTH<sub>2</sub>O, mmH<sub>2</sub>O, mm HG, & psi) measurement units
- 2 Lines 16 Characters (4.13H x 1.83W mm)
- Square root output indication (✓)

### Simple LCD Display Features

- Modular (may be added or removed in the field)
- Supports HART protocol variant
- 0, 90, 180, & 270 degree position adjustments
- Configurable (HART only) and standard (Pa, KPa, MPa, KGcm<sup>2</sup>, Torr, ATM, inH<sub>2</sub>O, mH<sub>2</sub>O, bar, mbar, inH<sub>2</sub>O, inHG, FTH<sub>2</sub>O, mmH<sub>2</sub>O, mm HG, & psi) measurement units.
- Supports Flow engineering units
- 2 Lines 6 digits PV (9.95H x 4.20W mm) 8 Characters
- Square root output indication (✓) and Write protect Indication
- Built in Basic Device Configuration through Internal Buttons – Range/Engineering Unit/Loop Test /Loop Calibration/Zero /Span Setting

## Diagnostics

SmartLine transmitters all offer digitally accessible diagnostics which aid in providing advanced warning of possible failure events minimizing unplanned shutdowns, providing **lower overall operational costs**

## System Integration

- SmartLine communications protocols all meet the most current published standards for HART/DE/Fieldbus.
- Integration with Honeywell's Experion PKS offers the following unique advantages.
  - Tamper reporting
  - FDM Plant Area Views with Health summaries
  - All ST 700 units are Experion tested to provide the highest level of compatibility assurance

## Configuration Tools

### External Three Button Configuration Option

Suitable for all electrical and environmental requirements, SmartLine offers the ability to configure the transmitter and display via three externally accessible buttons when a display option is selected. Zero/span capabilities are also optionally available via these buttons with or without selection of the display option.

### Internal Two Button Configuration Option

The Simple display has two buttons that can be used for Basic configuration such as re ranging, PV Engineering unit setting, Zero/Span settings and Loop testing and calibration functions.

### Hand Held Configuration

SmartLine transmitters feature two-way communication and configuration capability between the operator and the transmitter. This is accomplished via Honeywell's field-rated Multiple Communication Configurator (MCT404).

The MCT404 is capable of field configuring DE and HART Devices and can also be ordered for use in intrinsically safe environments. All Honeywell transmitters are designed and tested for compliance with the offered communication protocols and are designed to operate with any properly validated hand held configuration device.

### Personal Computer Configuration

Honeywell's SCT 3000 Configuration Toolkit provides an easy way to configure Digitally Enhanced (DE) instruments using a personal computer as the configuration interface. Field Device Manager (FDM) Software and FDM Express are also available for managing HART & Fieldbus device configurations.

## Modular Design

To help contain maintenance & inventory costs, all ST 700 transmitters are modular in design supporting the user's ability to replace meter bodies, add indicators or change electronic modules without affecting overall performance or approval body certifications. Each meter body is uniquely characterized to provide in-tolerance performance over a wide range of application variations in temperature and pressure and due to the Honeywell advanced interface, electronic modules may be swapped with any electronics module without losing in-tolerance performance characteristics.

### Modular Features

- Meter body replacement
  - Exchange/replace electronics/comms modules\*
  - Add or remove integral indicator\*
  - Add or remove lightning protection (terminal connection)\*
- \* Field replaceable in all electrical environments (including IS) except flameproof without violating agency approvals.

With no performance effects, Honeywell's unique modularity results in **lower inventory needs and lower overall operating costs**.

## Performance Specifications

**Reference Accuracy** (conformance to +/-3 Sigma)

Table 1

Model	URL	LRL	Min Span	Maximum Turndown Ratio	Stability (%URL/Year for ten years)	Reference Accuracy <sup>1,2</sup> (% Span)
STF724	400 in H <sub>2</sub> O/1000mbar	-400 in H <sub>2</sub> O/-1000mbar	4 in H <sub>2</sub> O/10.0mbar	100:1	0.02%	<b>0.050%</b>
STF72F	400 in H <sub>2</sub> O/1000mbar	-400 in H <sub>2</sub> O/-1000mbar	4 in H <sub>2</sub> O/10.0mbar	100:1	0.02%	<b>0.050%</b>
STF732	100 psi/7.0 bar	-100 psi/-7.0 bar	1 psi/0.07 bar	100:1	0.03%	<b>0.050%</b>
STF73F	100 psi/7.0 bar	-100 psi/-7.0 bar	1 psi/0.07 bar	100:1	0.03%	<b>0.050%</b>

Zero and span may be set anywhere within the listed (URL/LRL) range limits

**Accuracy, Span, Temperature and Static Pressure Effect: (Conformance to +/-3 Sigma)**

Table 2

		Accuracy <sup>1,2</sup> (% of Span)				Temperature Effect (%Span/50°F)		Static Line Pressure Effect (% Span/300psi)	
Model	URL	Turn down greater than	A	B	C (see URL Units)	D	E	F	G
STF724	400 in H <sub>2</sub> O(1000mbar)	16:1	0.0125	0.0375	25(62.5)	0.260	0.040	0.095	0.010
STF72F	400 in H <sub>2</sub> O (1000mbar)					0.050	0.020	0.025	0.005
Model	URL	Turn down greater than	A	B	C (see URL Units)	D	E	F	G
STF732	100 psi (7.0 bar)	4:1	0.0125	0.0375	25(1.7)	0.075	0.075	0.095	0.010
STF73F	100 psi (7.0 bar)					0.065	0.010	0.026	0.004
		Turn Down Effect $\pm \left[ A + B \left( \frac{C}{\text{Span}} \right) \right]$ % Span				Temp Effect $\pm \left[ D + E \left( \frac{\text{URL}}{\text{Span}} \right) \right]$ % Span per 28°C (50°F)		Static Effect $\pm \left[ F + G \left( \frac{\text{URL}}{\text{Span}} \right) \right]$ % Span per 300 psi	

**Total Performance (% of Span):**

$$\text{Total Performance} = \pm \sqrt{(\text{Accuracy})^2 + (\text{Temp Effect})^2 + (\text{Static Line Pressure Effect})^2}$$

**Total Performance Examples:** (5:1 Turndown, up to 50 °F shift & up to 300 psi Static Pressure)

**STF724 @ 80" H<sub>2</sub>O:** 0.485% of span

**STF72F @ 80" H<sub>2</sub>O:** 0.166% of span

**STF732 @ 20 psi:** 0.475 % of span

**STF73F@ 20 psi:** 0.137% of span

**Typical Calibration Frequency:**

Calibration verification is recommended every two (2) years

**Notes:**

1. Terminal Based Accuracy – Includes effects of linearity, hysteresis and repeatability. Analog output adds 0.005% of span
2. For zero based spans and reference conditions of 25°C, 0 psig static pressure, 10 to 55% RH.

## Operating Conditions – All Models

Parameter	Reference Condition		Rated Condition		Operative Limits		Transportation and Storage							
	°C	°F	°C	°F	°C	°F	°C	°F						
Ambient Temperature	25±1	77±2	-40 to 85	-40 to 185	-40 to 85	-40 to 185	-55 to 120	-67 to 248						
Meter Body Temperature	25±1	77±2	-40 to 110 <sup>1</sup>	-40 to 230 <sup>1</sup>	-40 to 125	-40 to 257	-55 to 120	-67 to 248						
Process Interface Temp. STF724, STF732 only	25±1	77±2	-40 to 110 <sup>1</sup>	-40 to 230 <sup>1</sup>	-40 to 175 <sup>2</sup>	-40 to 350 <sup>2</sup>	-55 to 125	-67 to 257						
Humidity %RH	10 to 55		0 to 100		0 to 100		0 to 100							
Minimum Pressure mmHg absolute inH <sub>2</sub> O absolute	atmospheric atmospheric		25 13		2 (short term <sup>3</sup> ) 1 (short term <sup>3</sup> )									
Supply Voltage	10.8 to 42.4 Vdc at terminals													
Load Resistance	0 to 1,440 ohms (as shown in <a href="#">Figure 2</a> )													

<sup>1</sup> Silicone 704 minimum temperature rating is 0°C (32°F). NEOBEE® M-20 minimum temperature rating is -15°C (5°F)  
NEOBEE® is a registered trademark of Stepan Company

<sup>2</sup> For CTFE fill fluid, the maximum temperature rating is 150°C (300°F)

<sup>3</sup> Short term equals 2 hours at 70°C (158 °F)

## Maximum Allowable Working Pressure (MAWP)<sup>5, 6</sup>

(ST 800 products are rated to Maximum Allowable Working Pressure. MAWP depends on Approval Agency and transmitter materials of construction.)

STF 724 & STF 732	Flange Material	Ambient Temperature -29 to 38°C [-20 to 100°F]	Max Meterbody Temperature 125°C [257°F]	Process Interface Temperature 175°C [350°F]
ANSI Class 150 <b>psi [bar]</b>	Carbon Steel	285 [19.6]	245 [16.9]	215 [14.8]
	304 S.S.	275 [19.0]	218 [15.0]	198 [13.7]
	316 S.S.	275 [19.0]	225 [15.5]	205 [14.1]
ANSI Class 300 <b>psi [bar]</b>	Carbon Steel	740 [51.0]	668 [46.0]	645 [44.5]
	304 S.S.	720 [49.6]	570 [39.3]	518 [35.7]
	316 S.S.	720 [49.6]	590 [40.7]	538 [37.1]
DN PN40 <b>psi [bar]</b>	Carbon Steel	580 [40.0] <sup>4</sup>	574 [39.6]	559 [38.5]
	304 S.S.	534 [36.8] <sup>4</sup>	419 [28.9]	385 [26.5]
	316 S.S.	534 [36.8] <sup>4</sup>	434 [29.9]	399 [27.5]
STF72F& STF73F ANSI Class 150 psi [bar]	316L Stainless Steel	230 [15.9]	185 [12.8]	No rating at this temp

<sup>4</sup> Ambient Temperature for DN PN40 is -10 to 50°C [14 to 122 F]

<sup>5</sup> MAWP applies for temperature range -40 to 125°C. However, Static Pressure Limit is de-rated to 3,000 psi from -26°C to -40°C.

Use of graphite o-rings de-rates transmitter to 3,625 psi. Use of adaptor with graphite o-rings de-rates transmitter to 3,000 psi.

<sup>6</sup> Consult factory for MAWP of ST 800 transmitters with CSA approval.




Figure 2 - Supply voltage and loop resistance chart &amp; calculations

### Performance Under Rated Conditions – All Models

Parameter	Description	
Analog Output Digital Communications:	Two-wire, 4 to 20 mA (HART & DE Transmitters only) Honeywell DE, HART 7 protocol or FOUNDATION Fieldbus ITK 6.0.1 compliant All transmitters, irrespective of protocol have polarity insensitive connection.	
HART & DE Output Failure Modes (NAMUR for DE Units requires selecting display and configuration buttons or factory configuration)	Normal Limits: Failure Mode:	Honeywell Standard: NAMUR NE 43 Compliance: 3.8 – 20.8 mA $\leq 3.6 \text{ mA}$ and $\geq 21.0 \text{ mA}$ 3.8 – 20.5 mA $\leq 3.6 \text{ mA}$ and $\geq 21.0 \text{ mA}$
Supply Voltage Effect	0.005% span per volt.	
Transmitter Turn on Time (includes power up & test algorithms)	HART or DE: 2.5 sec.	Foundation Fieldbus: Host dependant
Response Time (delay + time constant)	<u>DE/HART Analog Output</u> 90mS	<u>FOUNDATION Fieldbus</u> 150mS (Host Dependant)
Damping Time Constant	HART: Adjustable from 0 to 32 seconds in 0.1 increments. Default: 0.50 seconds DE: Discrete values 0, .16, .32, .48, 1, 2, 4, 8, 16, 32 seconds. Default: 0.48 seconds	
Vibration Effect	Less than +/- 0.1% of URL w/o damping Per IEC60770-1 field or pipeline, high vibration level (10-2000Hz: 0.21 displacement/3g max acceleration)	
Electromagnetic Compatibility	IEC 61326-3-1	
Lightning Protection Option	Leakage Current: 10uA max @ 42.4VDC 93C Impulse rating: 8/20uS 5000A (>10 strikes) 10000A (1 strike min.) 10/1000uS 200A (> 300 strikes)	

**Materials Specifications** (see model selection guide for availability/restrictions with various models)

Parameter	Description
Barrier Diaphragms Material	316L SS, Hastelloy® C-276 <sup>2</sup> , Monel® 400 <sup>**3</sup>
Process Head Material	316 SS <sup>4</sup> , Carbon Steel (Zinc-plated) <sup>5</sup> , Hastelloy C-276 <sup>*6</sup> , Monel 400 <sup>**7</sup>
Vent/Drain Valves & Plugs <sup>1</sup>	316 SS <sup>4</sup> , Hastelloy C-276 <sup>2</sup> , Monel 400 <sup>7</sup>
Gasket Ring Material (Wetted)	316/316L SS, Hastelloy® C-276 <sup>*2</sup> , Monel®400 <sup>**3</sup>
Extension Tube Material	316 SS <sup>4</sup>
Head Gaskets	Glass-filled PTFE standard. Viton® and graphite are optional.
Meter Body Bolting	Carbon Steel (Zinc plated) standard. Options include 316 SS, NACE A286 SS bolts, Monel K500, Super Duplex and B7M.
Optional Adapter Flange and Bolts	Adapter Flange materials include 316 SS <sup>4</sup> , Hastelloy C-276 <sup>6</sup> and Monel 400 <sup>7</sup> . Bolt material for flanges is dependent on process head bolts material chosen. Standard adaptor seal material is glass-filled PTFE. Viton and graphite are optional.
Mounting Flange <b>STF724, STF732</b> <b>STF72F, STF73F</b>	<b>Flush or Extended Diaphragm:</b> Zinc Chromate plated Carbon Steel <sup>5</sup> , 304 SS, or 316 SS <sup>4</sup> . <b>316L SS</b> ( <i>NOTE: Mounting Flange is process wetted.</i> )
Fill Fluid	Silicone 200, CTFE, NEOBEE M-20 or Silicone 704
Electronic Housing	Pure Polyester Powder Coated Low Copper (<0.4%)-Aluminum. Meets NEMA 4X, IP66, & P67. All stainless steel housing is optional.
Mounting	See <a href="#">Figure 3</a> for typical flange mounting arrangement.
Process Connections <b>All Models</b> <b>STF724, STF732</b> <b>STF72F, STF73F</b>	<b>Process Head:</b> 1/4-inch NPT; 1/2-inch NPT with adapter and DIN, standard options. <b>Flange:</b> 2, 3 or 4-inch Class 150 or 300 ANSI; DN50-PN40, DN80-PN40 or DN100-PN40 DIN flange. <b>Extended Diaphragm:</b> 2, 4, or 6 inches (50, 101, 152 mm) long. <b>2 or 3-inch, Class 150 ANSI flange.</b>
Wiring	Accepts up to 16 AWG (1.5 mm diameter).
Dimensions	See <a href="#">Figure 4</a> , <a href="#">Figure 5</a> & <a href="#">Figure 6</a>
Net Weight	<b>STF72F, STF73F:</b> 14-19 pounds (6.4 - 8.7Kg) with Aluminum Housing <b>STF724, STF732:</b> 18-32 pounds (8.2 - 14.5Kg) with Aluminum Housing

<sup>1</sup> Vent/Drains are sealed with Teflon®

<sup>2</sup> Hastelloy C-276 or UNS N10276

<sup>3</sup> Monel 400 or UNS N04400

<sup>4</sup> Supplied as 316 SS or as Grade CF8M, the casting equivalent of 316 SS.

<sup>5</sup> Carbon Steel heads are zinc-plated and not recommended for water service due to hydrogen migration. For that service, use 316 stainless steel wetted Process Heads.

<sup>6</sup> Hastelloy C-276 or UNS N10276. Supplied as indicated or as Grade CW12MW, the casting equivalent of Hastelloy C-276

<sup>7</sup> Monel 400 or UNS N04400. Supplied as indicated or as Grade M30C, the casting equivalent of Monel 400

\* Flush design only.

\*\*Flush or pseudo flange design.

## Communications Protocols & Diagnostics

### HART Protocol

#### Version:

HART 7

#### Power Supply

Voltage: 10.8 to 42.4Vdc at terminals

Load: Maximum 1440 ohms See [Figure 2](#).

Minimum Load: 0 ohms. (For handheld communications a minimum load of 250 ohms is required)

### Foundation Fieldbus (FF)

#### Power Supply Requirements

Voltage: 9.0 to 32.0Vdc at terminals

Steady State Current: 17.6mAdc

Software Download Current: 27.4mAdc

#### Available Function Blocks

Block Type	Qty	Execution Time
Resource	1	n/a
Transducer	1	n/a
Diagnostic	1	n/a
Analog Input	1*	30 ms
PID w/Autotune	1	45 ms
Integrator	1	30 ms
Signal Char (SC)	1	30 ms
LCD Display	1	n/a
Flow Block	1	30 ms
Input Selector	1	30 ms
Arithmetic	1	30 ms

\* AI block may have two (2) additional instantiations.

All available function blocks adhere to FOUNDATION Fieldbus standards. PID blocks support ideal & robust PID algorithms with full implementation of Auto-tuning.

#### Link Active Scheduler

Transmitters can perform as a backup Link Active Scheduler and take over when the host is disconnected. Acting as a LAS, the device ensures scheduled data transfers typically used for the regular, cyclic transfer of control loop data between devices on the Fieldbus.

#### Number of Devices/Segment

Entity IS model: 6 devices/segment

#### Schedule Entries

18 maximum schedule entries

#### Number of VCR's: 24 max

**Compliance Testing:** Tested according to ITK 6.0.1

### Software Download

Utilizes Class-3 of the Common Software Download procedure as per FF-883 which allows the field devices of any manufacturer to receive software upgrades from any host.

### Honeywell Digitally Enhanced (DE)

DE is a Honeywell proprietary protocol which provides digital communications between Honeywell DE enabled field devices and Hosts.

#### Power Supply

Voltage: 10.8 to 42.4Vdc at terminals

Load: Maximum 1440 ohms See [Figure 2](#).

#### Standard Diagnostics

ST 700 top level diagnostics are reported as either critical or non-critical and readable via the DD/DTM tools or integral display as shown below.

#### Critical Diagnostics

HART DD/DTM Tools	Basic Display	Simple Display
Electronic Module DAC Failure	Electronics module fault	Fault Comm El
Meter Body NVM Corrupt	Meter Body fault	Fault Mtrbody
Config. Data Corrupt	Electronics module fault	Fault Comm El
Electronic Module Diag Failure	Electronics module fault	Fault Comm El
Meter Body Critical Failure	Meter Body fault	Fault Mtrbody
Sensor Comms Timeout	Meter Body Comm fault	Fault Mbd Com

#### Non-Critical Diagnostics

HART DD/DTM Tools
Display Failure
Electronic Module Comm Failure
Meter Body Excess Correct
Sensor Over Temperature
Fixed Current Mode
PV Out of Range
No Factory Calibration
No DAC Compensation
LRV Set Error – Zero Config. Button
URV Set Error – Zero Config. Button
AO Out of Range
Loop Current Noise
Meter Body Unreliable Comm
Tamper Alarm,
No DAC Calibration
Sensor Supply Voltage Low

Refer to ST 700 manuals for additional level diagnostic information.

## Approval Certifications:

AGENCY	TYPE OF PROTECTION	COMM. OPTION	FIELD PARAMETERS	AMBIENT TEMP (Ta)
FM Approvals™	<b>Explosionproof:</b> Class I, Division 1, Groups A, B, C, D; <b>Dust Ignition Proof:</b> Class II, III, Division 1, Groups E, F, G; T4  Class I, Zone 0/1, AEx d IIC Ga/Gb Class II, Zone 21, AEx tb IIIC Db T 95°C	All	Note 1	T5: -50 °C to 85°C T6: -50 °C to 65°C
	<b>Intrinsically Safe:</b> Class I, II, III, Division 1, Groups A, B, C, D, E, F, G; T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
	Class I, Zone 0, AEx ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Class I, Division 2, Groups A, B, C, D locations,  Class I, Zone 2, AEx nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure:</b> Type 4X/ IP66/ IP67	All	All	-
Canadian Standards Association (CSA)	<b>Explosion Proof:</b> Class I, Division 1, Groups A, B, C, D; <b>Dust Ignition Proof:</b> Class II, III, Division 1, Groups E, F, G;  Ex d IIC Ga Ex tb IIIC Db T 95°C	All	Note 1	T5: -50 °C to 85°C T6: -50 °C to 65°C
	<b>Intrinsically Safe:</b> Class I, II, III, Division 1, Groups A, B, C, D, E, F, G; T4  Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Class I, Division 2, Groups A, B, C, D; T4  Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure:</b> Type 4X/ IP66/ IP67	All	All	-

**Approval Certifications: (Continued)**

<b>ATEX</b>	<b>Flameproof:</b> II 1/2 G Ex d IIC Ga/Gb II 2 D Ex tb IIIC Db T 95°C	All	Note 1	T5: -50 °C to 85°C T6: -50 °C to 65°C
	<b>Intrinsically Safe:</b> II 1 G Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> II 3 G Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure:</b> IP66/ IP67	All	All	-
<b>IECEx (World)</b>	<b>Flameproof :</b> Ex d IIC Ga/Gb T4 Ex tb IIIC Db T 95°C	All	Note 1	T5: -50 °C to 85°C T6: -50 °C to 65°C
	<b>Intrinsically Safe:</b> Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure:</b> IP66/ IP67	All	All	-
<b>SAEx (South Africa)</b>	<b>Flameproof :</b> Ex d IIC Ga/Gb T4 Ex tb IIIC Db T 95°C	All	Note 1	-50 °C to 85°C
	<b>Intrinsically Safe:</b> Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure:</b> IP66/ IP67	All	All	-
<b>INMETRO (Brazil)</b>	<b>Flameproof:</b> Ex d IIC Ga/ Gb T4 Ex tb IIIC Db T 95°C	All	Note 1	-50 °C to 85°C
	<b>Intrinsically Safe:</b> Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
	<b>Enclosure :</b> IP 66/67	All	All	-

**Approval Certifications: (Continued)**

<b>NEPSI (China)</b>	<b>Flameproof:</b> Ex d IIC Ga/Gb T4 Ex tb IIIC Db T 85°C	All	Note 1	-50 °C to 85°C
	<b>Intrinsically Safe:</b> Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Nonincendive:</b> Ex nA IIC Gc T4	4-20 mA / DE/ HART/ Foundation Fieldbus	Note 1	-50 °C to 85°C
<b>Enclosure :</b> IP 66/67		All	All	-
<b>GOST</b>	<b>Flameproof:</b> 1 Ex d IIC Ga/Gb T4 Ex tb IIIC Db T 85°C	All	Note 1	-50 °C to 85°C
	<b>Intrinsically Safe:</b> 0 Ex ia IIC Ga T4  FISCO Field Device (Only for FF Option) Ex ia IIC T4	4-20 mA / DE/ HART	Note 2a	-50 °C to 70°C
		Foundation Fieldbus	Note 2b	-50 °C to 70°C
	<b>Enclosure :</b> IP 66/67	All	All	

Notes:

## 1. Operating Parameters:

$$\begin{array}{ll} \text{Voltage}= 11 \text{ to } 42 \text{ V DC} & \text{Current}= 4-20 \text{ mA Normal} \\ & = 10 \text{ to } 30 \text{ V (FF)} \\ & & = 30 \text{ mA (FF)} \end{array}$$

## 2. Intrinsically Safe Entity Parameters

## a. Analog/ DE/ HART Entity Values:

$$\text{Vmax= } \text{Ui } = 30\text{V} \quad \text{Imax= } \text{li= } 105\text{mA} \quad \text{Ci } = 4.2\text{nF} \quad \text{Li } = 984 \text{ uH} \quad \text{Pi } = 0.9\text{W}$$

Transmitter with Terminal Block Revision E or Later

$$\text{Vmax= } \text{Ui } = 30\text{V} \quad \text{Imax= } \text{li= } 225\text{mA} \quad \text{Ci } = 4.2\text{nF} \quad \text{Li } = 0 \quad \text{Pi } = 0.9\text{W}$$

Note : Transmitter with Terminal Block Revision E or later

The revision is on the label that is on the module. There will be two lines of text on the label:

- First is the Module Part #: 50049839-001 or 50049839-002
- Second line has the supplier information, along with the REVISION:

XXXXXXXX-XXXX, THE "X" is production related, THE POSITION of the "E" IS THE REVISION.

## b. Foundation Fieldbus- Entity Values

$$\text{Vmax= } \text{Ui } = 30\text{V} \quad \text{Imax= } \text{li= } 180\text{mA} \quad \text{Ci } = 0\text{nF} \quad \text{Li } = 984 \text{ uH} \quad \text{Pi } = 1\text{W}$$

Transmitter with Terminal Block Revision F or Later

$$\text{Vmax= } \text{Ui } = 30\text{V} \quad \text{Imax= } \text{li= } 225\text{mA} \quad \text{Ci } = 0\text{nF} \quad \text{Li } = 0 \quad \text{Pi } = 1 \text{ W}$$

$$\text{FISCO Field Device} \quad \text{Imax= } \text{li= } 380 \text{ mA} \quad \text{Ci } = 0\text{nF} \quad \text{Li } = 0 \quad \text{Pi } = 5.32 \text{ W}$$

$$\text{Vmax= } \text{Ui } = 17.5\text{V}$$

Note : Transmitter with Terminal Block Revision F or later

The revision is on the label that is on the module. There will be two lines of text on the label:

- First is the Module Part #: 50049839-003 or 50049839-004
- Second line has the supplier information, along with the REVISION:

XXXXXXXX-XXXX, THE "X" is production related, THE POSITION of the "E" IS THE REVISION.

### Approval Certifications: (Continued)

<b>Marine Certificates</b>	This certificate defines the certifications covered for the ST 800 Pressure Transmitter family of products, including the SMV 800 Smart Multivariable Transmitter. It represents the compilation of the five certificates Honeywell currently has covering the certification of these products into marine applications.
	For SmartLine Pressure Transmitter and SMV800 Smart Multivariable Transmitter
	<b>American Bureau of Shipping (ABS)</b> - 2009 Steel Vessel Rules 1-1-4/3.7, 4-6-2/5.15, 4-8-3/13 & 13.5, 4-8-4/27.5.1, 4-9-7/13. Certificate number: 04-HS417416-PDA
	<b>Bureau Veritas (BV)</b> - Product Code: 389:1H. Certificate number: 12660/B0 BV
	<b>Det Norske Veritas (DNV)</b> - Location Classes: Temperature D, Humidity B, Vibration A, EMC B, Enclosure C. For salt spray exposure; enclosure of 316 SST or 2-part epoxy protection with 316 SST bolts to be applied. Certificate number: A-11476
	<b>Korean Register of Shipping (KR)</b> - Certificate number: LOX17743-AE001
	<b>Lloyd's Register (LR)</b> - Certificate number: 02/60001(E1) & (E2)
<b>SIL 2/3 Certification</b>	IEC 61508 SIL 2 for non-redundant use and SIL 3 for redundant use according to EXIDA and TÜV Nord Sys Tec GmbH & Co. KG under the following standards: IEC61508-1: 2010; IEC 61508-2: 2010; IEC61508-3: 2010.

### Other Certification Options

#### Materials

- NACE MRO175, MRO103, ISO15156

### Dimensional Drawings




Figure 3 – Typical mounting for flange mounted level transmitter

## Dimensional Drawings (con't)




Figure 4 – Typical mounting dimensions for flush diaphragm type models STF724 and STF732.

## Dimensional Drawings (con't)




Figure 5 – Typical mounting dimensions for extended diaphragm type models STF724 and STF732.

## Dimensional Drawings (con't)




Figure 6 – Typical mounting dimensions for pseudo flange type models STF72F, STF73F, and STF74F.

Model Selection Guides are subject to change and are inserted into the specifications as guidance only.  
 Prior to specifying or ordering a model check for the latest revision Model Selection Guides which are published at:  
[www.honeywellprocess.com/en-US/pages/default.aspx](http://www.honeywellprocess.com/en-US/pages/default.aspx)

## Model Selection Guide

# Model STF700 Flange Mounted Liquid Level Transmitter

Model Selection Guide  
34-ST-16-103 Issue 12

### Instructions

- Select the desired Key Number. The arrow to the right marks the selection available.
- Make one selection from each Table (I, II and IX) using the column below the proper arrow.
- A(•) denotes unrestricted availability. A letter denotes restricted availability.
- Restrictions follow Table IX.

Key Number	I	II	III	IV	V	VI	VII	VIII	IX
STF7 ____ - _____ - _____ - _____ - _____ - _____ - _____ - _____ + 0 0 0 0									

KEY NUMBER	URL	LRL	Max Span	Min Span	Units	Selection	Availability
Measurement Range Std Accuracy	400 (1000)	-400 (-1000)	400 (1000)	4 (10)	" H <sub>2</sub> O (mbar)	STF724	↓
	100 (7)	-100 (-7)	100 (7)	1 (0.07)	psi (bar)	STF732	↓
	400 (1000)	-400 (-1000)	400 (1000)	1 (2.5)	" H <sub>2</sub> O (mbar)	STF72F	↓
	100 (7)	-100 (-7)	100 (7)	1 (0.07)	psi (bar)	STF73F	↓

TABLE I	Materials of Construction	Design	Ref. Head	Vent Drain Valve on Ref. Head <sup>2</sup>	Barrier Diaphrm. (wetted)	Diaphrm. Plate (wetted)	Extension (wetted)	Sel.				
Meter Body & Flange Design	a. Process Wetted Heads & Diaphragm Materials	Flush	Carbon <sup>1</sup> Steel	316 SS	316L SS	316L SS	N/A	A_____	•			
			316 SS <sup>5</sup>		316L SS	316L SS		W_____	•			
			Hast C <sup>3,6</sup>		Hast C <sup>3</sup>	Hast C <sup>3</sup>		B_____	•			
		Extended	Carbon <sup>1</sup> Steel	316 SS	316L SS	316L SS	316L SS	E_____	•			
			316 SS <sup>5</sup>		316L SS	316L SS		X_____	•			
			Hast C <sup>3,6</sup>		Hast C <sup>3</sup>	Hast C <sup>3</sup>		F_____	•			
		Pseudo Flange	Carbon <sup>1</sup> Steel	316 SS	316L SS	316L SS	N/A	J_____	•			
			316 SS <sup>5</sup>		316L SS	316L SS		M_____	•			
			Hast C <sup>3,6</sup>		Hast C <sup>3</sup>	Hast C <sup>3</sup>		N_____	•			
		b. Fill Fluid (Meter Body & Flange)	Silicone Oil 200					_1_____	•	•		
			Fluorinated Oil CTFE					_2_____	•	•		
			Silicone Oil 704					_3_____	•	•		
			NEOBEE® M-20					_4_____	•	•		
	c. Process Connection	Reference Head		Range		Sel.						
		1/4 NPT		High Pressure Side	____A____	____C____						
		1/2 NPT Adapter - material matches head material and head bolt material <sup>11</sup>			____B____	____D____						
		1/2 NPT Adapter - material matches head material and head bolt material <sup>11</sup>		Low Pressure Side	____H____	____J____						
	d. Bolts for Process Heads	Carbon Steel Bolts					____C____		•	•		
		316 SS Bolts					____S____		•	•		
		A286 SS (NACE) Bolts					____N____		•	•		
		B7M Bolts					____B____		•	•		
	e. Vent/Drain Type/Location	Ref. Head Type	Vent Type	Location	Vent Material		Sel.					
		Single Ended	None	None	None		____1____		•	•		
		Single Ended	Std	Side	Matches Head Material <sup>11</sup>		____2____		•	•		
		Single Ended	Ctr	Side	Stainless Steel Only		____3____		t	t		
		Dual Ended	Std	End	Matches Head Material <sup>11</sup>		____4____		•	•		
		Dual Ended	Ctr	End	Stainless Steel Only		____5____		t	t		
		Dual Ended	Vent/Plug	Side/End	Matches Head Material <sup>11</sup>		____6____		•	•		
	f. Gasket Material	Teflon® or PTFE (Glass Filled)					____A____		•	•		
		Viton® or Fluorocarbon Elastomer					____B____		•	•		

<sup>1</sup> Carbon Steel heads are zinc-plated and not recommended for water service due to hydrogen migration. For that service, use the 316 stainless steel Wetted Reference Head.

<sup>2</sup> Vent/Drains are Teflon or PTFE coated for lubricity.

<sup>3</sup> Hastelloy® C-276 or UNS N10276

<sup>5</sup> Supplied as 316 SS or as Grade CF8M, the casting equivalent of 316 SS.

<sup>6</sup> Supplied as indicated or as Grade CW12MW, the casting equivalent of Hastelloy® C-276

<sup>11</sup> Except Carbon Steel Heads shall use 316SS Vent/Drain, Plugs & Adapters when required

TABLE II			Flange Material	Threaded Nut Ring Material	Selection	Availability		
						STF7xx	↓ 24 32	↓ 2F 3F
Flange Assembly	(ANSI Flanges have 125-500 AARH Surface Finish)	a. Flange	Carbon Steel (non-wetted)	Carbon Steel (non-wetted)	1 --	●		
					2 --	●		
					3 --	●		
					4 --	●		
					5 --	●		
					6 --	●		
					7 --	●		
					8 --	●		
					9 --	●		
		304 SS (non-wetted)	304 SS (non-wetted)	A --	●			
				B --	●			
				C --	●			
				D --	●			
				E --	●			
		316 SS (non-wetted)	304 SS (non-wetted)	F --	●			
				Q --	●			
				U --	●			
				V --	●			
				H --	●			
				J --	●			
				K --	●			
				L --	●			
				M --	●			
		Pseudo Flange on Standard DP	316L SS (wetted)	N --	●			
				W --	●			
				X --	●			
				Z --	●			
				S --			●	
		b. Gasket Ring (wetted)	Not Applicable	T --			●	
				P --			●	
				R --			●	
		No Selection		- 0 -			●	
		Flush Design	316L SS Hastelloy® C <sup>3</sup>	- 1 -	s			
		Extended Design		- 2 -	s			
		c. Extension (wetted)	316L SS	- 5 -	v			
				No Selection	0		●	
				Flush	F	w		
				Diameter	Length	Sel.		
				1.87 Inches (for 2", 3" or 4" spud) <sup>13</sup>	2 inches 4 inches 6 inches	C D E	v v v	

<sup>3</sup> Hastelloy® C-276 or UNS N10276<sup>13</sup> For part numbers and pricing information on Tank Spuds refer to page ST-91 (Supplementary Accessories & Kits).

TABLE III	Agency Approvals (see data sheet for Approval Code Details)	Selection
Approvals	No Approvals Required	0
	FM Explosion proof, Intrinsically Safe, Non-incendive, & Dustproof	*
	CSA Explosion proof, Intrinsically Safe, Non-incendive, & Dustproof	*
	ATEX Explosion proof, Intrinsically Safe & Non-incendive	*
	IECEx Explosion proof, Intrinsically Safe & Non-incendive	*
	SAEx/CCoE Explosion proof, Intrinsically Safe & Non-incendive	*
	INMETRO Explosion proof, Intrinsically Safe & Non-incendive	*
	NEPSI Explosion proof, Intrinsically Safe & Non-incendive	*
		G

				Availability		
				STF7xx	↓	↓
a. Electronic Housing Material & Connection Type	TRANSMITTER ELECTRONICS SELECTIONS			Selection	24 32	2F 3F
	Material	Connection	Lightning Protection	A_ _	*	*
	Polyester Powder Coated Aluminum	1/2 NPT	None	B_ _	*	*
	Polyester Powder Coated Aluminum	M20	None	C_ _	*	*
	Polyester Powder Coated Aluminum	1/2 NPT	Yes	D_ _	*	*
	Polyester Powder Coated Aluminum	M20	Yes	E_ _	*	*
	316 Stainless Steel (Grade CF8M)	1/2 NPT	None	F_ _	*	*
	316 Stainless Steel (Grade CF8M)	M20	None	G_ _	*	*
	316 Stainless Steel (Grade CF8M)	1/2 NPT	Yes	H_ _	*	*
b. Output/ Protocol	Analog Output		Digital Protocol			
	4-20mA dc		HART Protocol		_ H_ _	*
	4-20mA dc none		DE Protocol Foundation Fieldbus		_ D_ _	*
c. Customer Interface Selections	Indicator	Ext Zero, Span & Config Buttons		Languages		
	None	None		__ 0	*	*
	None	Yes (Zero/Span Only)		__ A	f	f
	Basic	None		__ B	*	*
	Basic	Yes		__ C	*	*
Simple (w/internal Zero, Span & Conf Buttons)		None		__ D	u	u

TABLE V	CONFIGURATION SELECTIONS			Selection	
	Diagnostics			1_ _	*
a. Application Software	Standard Diagnostics				*
	Write Protect	Fail Mode	High & Low Output Limits <sup>3</sup>	_ 1_ _	f
	Disabled	High> 21.0mAdc	Honeywell Std (3.8 - 20.8 mAdc)	_ 2_ _	f
	Disabled	Low< 3.6mAdc	Honeywell Std (3.8 - 20.8 mAdc)	_ 3_ _	f
	Enabled	High> 21.0mAdc	Honeywell Std (3.8 - 20.8 mAdc)	_ 4_ _	f
	Enabled	Low< 3.6mAdc	Honeywell Std (3.8 - 20.8 mAdc)	_ 5_ _	g
b. Output Limit, Failsafe & Write Protect Settings	N/A	N/A	N/A Fieldbus	_ 6_ _	g
	Disabled	N/A	N/A Fieldbus		g
c. General Configuration	Factory Standard			-- S	*
	Custom Configuration (Unit Data Required from customer)			-- C	*

<sup>3</sup> NAMUR Output Limits 3.8 - 20.5mAdc can be configured by the customer or select custom configuration Table Vc

TABLE VI	CALIBRATION & ACCURACY SELECTIONS			Selection	
	Accuracy	Calibrated Range	Calibration Qty	A	*
Accuracy and Calibration	Standard	Factory Std	Single Calibration	B	*
	Standard	Custom (Unit Data Required)	Single Calibration		*

TABLE VII	ACCESSORY SELECTIONS			Selection	
	a. Mounting Bracket	None (not required with flange mount unit)			0_ _ _
b. Customer Tag	No customer tag			_ 0_ _ _	*
	One Wired Stainless Steel Tag (Up to 4 lines 26 char/line)			_ 1_ _ _	*
	Two Wired Stainless Steel Tag (Up to 4 lines 26 char/line)			_ 2_ _ _	*
c. Unassembled Conduit Plugs & Adapters	No Conduit Plugs or Adapters Required 1/2 NPT Male to 3/4 NPT Female 316 SS Certified Conduit Adapter 1/2 NPT 316 SS Certified Conduit Plug M20 316 SS Certified Conduit Plug Minifast® 4 pin (1/2 NPT) Minifast® 4 pin (M20)			-- A0	*
				-- A2	n
				-- A6	n
				-- A7	m
				-- A8	n
				-- A9	m

<b>TABLE VIII</b>		<b>OTHER Certifications &amp; Options: (String in sequence comma delimited (XX, XX, XX,...))</b>	<b>Selection</b>		
<b>Certifications &amp; Warranty</b>	None - No additional options		00	*	*
	NACE MR0175; MR0103; ISO15156 (FC33338) Process wetted parts only		FG	*	*
	NACE MR0175; MR0103; ISO15156 (FC33339) Process wetted and non-wetted parts		F7	c	c
	Marine (DNV, ABS, BV, KR, LR)		MT	i	i
	EN10204 Type 3.1 Material Traceability (FC33341)		FX	*	*
	Certificate of Conformance (F3391)		F3	*	*
	Calibration Test Report & Certificate of Conformance (F3399)		F1	*	*
	Certificate of Origin (F0195)		F5	*	*
	FMEDA (SIL 2/3) Certification (FC33337)		FE	j	j
	Over-Pressure Leak Test Certificate (1.5X MAWP) (F3392)		TP	*	*
	Cert Clean for O <sub>2</sub> or Cl <sub>2</sub> service per ASTM G93		OX	e	e
PMI Certification			PM	*	*

<b>TABLE IX</b>	<b>Manufacturing Specials</b>			
<b>Factory</b>	<b>Factory Identification</b>		0000	*

#### MODEL RESTRICTIONS

<b>Restriction Letter</b>	<b>Available Only with</b>		<b>Not Available with</b>	
	<b>Table</b>	<b>Selection(s)</b>	<b>Table</b>	<b>Selection(s)</b>
a			VIII	FG, F7
b	Select only one option from this group			
c	l <sup>d</sup>	_N,B__		
e	l <sup>b</sup>	_2____		
f			IVb	_F_
g			IVb	_H,D_
i	IVa	C,D,G,H__		
j	IVb	_H_	Vb	_1,2,5,6,_
m	IVa	B,D,F,H__		
n	IVa	A,C,E,G__		
s	l <sup>a</sup>	A,W,B,E,X,F,J_____		
t			l <sup>a</sup>	J_____
u	IVb	_H_		
v	l <sup>a</sup>	M,N,R,S_____		
w			l <sup>a</sup>	M,N,R,S_____
			l <sup>b</sup>	_5_

## Sales and Service

For application assistance, current specifications, pricing, or name of the nearest Authorized Distributor, contact one of the offices below.

### ASIA PACIFIC

Honeywell Process Solutions,  
(TAC) [hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

#### Australia

Honeywell Limited  
Phone: +(61) 7-3846 1255  
FAX: +(61) 7-3840 6481  
Toll Free 1300-36-39-36  
Toll Free Fax:  
1300-36-04-70

#### China – PRC - Shanghai

Honeywell China Inc.  
Phone: (86-21) 5257-4568  
Fax: (86-21) 6237-2826

#### Singapore

Honeywell Pte Ltd.  
Phone: +(65) 6580 3278  
Fax: +(65) 6445-3033

#### South Korea

Honeywell Korea Co Ltd  
Phone: +(822) 799 6114  
Fax: +(822) 792 9015

### EMEA

Honeywell Process Solutions,  
Phone: + 80012026455 or  
+44 (0)1344 656000

Email: (Sales)

[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)

or

(TAC)

[hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

### AMERICA'S

Honeywell Process Solutions,  
Phone: (TAC) 1-800-423-9883 or  
215/641-3610  
(Sales) 1-800-343-0228

Email: (Sales)

[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)

or

(TAC)

[hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

*Specifications are subject to change without notice.*

**For more information**

To learn more about SmartLine Pressure  
Transmitters visit [www.honeywellprocess.com](http://www.honeywellprocess.com)  
Or contact your Honeywell Account Manager

**Process Solutions**

Honeywell  
1250 W Sam Houston Pkwy S  
Houston, TX 77042

Honeywell Control Systems Ltd  
Honeywell House, Skimmed Hill Lane  
Bracknell, England, RG12 1EB

Shanghai City Centre, 100 Jungi Road  
Shanghai, China 20061



34-ST-03-103  
February 2018

©2018 Honeywell International Inc.

[www.honeywellprocess.com](http://www.honeywellprocess.com)